



STATE OF ARIZONA
DEPARTMENT OF EMERGENCY AND MILITARY AFFAIRS
DEMA Procurement Office, Building #M5330
5636 East McDowell Road
Phoenix, Arizona 85008-3495.

SOLICITATION NUMBER: M9-0034

Purchase and installation of four (4) complete Class "A" Fire Alarm systems @ Casa Grande Readiness Center, Coolidge Readiness Center, Prescott Readiness Center, Sunnyslope Readiness Center in Arizona.

SOLICITATION AMENDMENT # Five (5)

ISSUE DATE: 4/24/09

AMENDMENT

The following changes, additions, and/or deletions are for the above noted solicitation. All other terms and conditions shall remain the same.

This amendment must be signed and returned with the offer.

This amendment forms a part of the contractual documents/solicitation and modifies them as follows:

1. Exhibit 1, Scope of Work, Section 1.2.
Scope of work includes the following buildings/building numbers:

Casa Grande -- L2120

Coolidge -- L3160 & L3161



Prescott -- Y5380

Sunnyslope -- M8360 & M8361

Exclude all other structures onsite.

2. Exhibit 1, Scope of Work.
Gas shutoff solenoid valves via Fire Alarm Systems for space heaters are not required but may be included by the Contractor.
3. Exhibit 1, Scope of Work.
Existing Kitchen Hood Suppression Systems are not required to be monitored by the proposed Fire Alarm System but may be included by the Contractor.

END OF AMENDMENT

<p>Name and Title of Procurement Officer</p> <p>Corry Slama, C.P.M., CPPB Procurement Manager</p>	<p>Offeror hereby acknowledges receipt and understanding of this amendment.</p>
<p> As Procurement Officer and not personally</p> <p> Date</p>	<p>Signature _____ Date _____</p> <p>Type/Printed Name _____</p> <p>Title _____</p> <p>Company Name _____</p> <p>Address _____</p> <p>City _____ State _____ Zip Code _____</p>